

# **Energy Guidelines for District Buildings**

## District Temperature Setting Standard

### Heating season:

#### Classrooms/Media Centers:

Pre-school and kindergarten	72 – 74 degrees
1 <sup>st</sup> through 5 <sup>th</sup> grade	70 – 72 degrees
6 <sup>th</sup> through 12 <sup>th</sup> grade	68 – 70 degrees

#### Offices:

All Locations	68 – 70 degrees
---------------	-----------------

#### Corridors:

All Locations	62 degrees
---------------	------------

#### Commons Spaces:

Auditoriums, Gym, Cafeteria	68 degrees
-----------------------------	------------

Warehouse, Maintenance Shops	65 degrees –Maximum
------------------------------	---------------------

#### Night Thermostats/Unoccupied Periods:

All Locations	55 degrees
---------------	------------

<u>Cooling Season:</u>	74 – 76 degrees
------------------------	-----------------